

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	4076-2334:0503
CATEGORY:	4076 - SMOKE & DRAFT CONTROL FOR FIRE DOOR
LISTEE:	ASA, GP 12310 Pinecrest Rd, Suite 300, Reston, VA, 20191 Contact: Sadeghian,Dr. Steven Email: Asagp85@gmail.com
DESIGN:	Model SD60GS Elevator Smoke Curtain System. The product consists of an enclosed single roller galvanized steel head box face mounted at the header in front of the opening, with side guides attached flush with the sides of the opening extending from the head box to floor level. A single panel of model SD60GS fabric with a 56" wide by 30" tall plastic view panel is hung from the head box and inside the side guides. The SD60GS fabric is manufactured from woven glass fiber fabric coated on each side with silver polyurethane. The side guides and head box are sealed with 3M CP 25WB+ fire barrier sealant.
	Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	UL 1784: 0.10" water column: 0.30 scfm/ft²
	0.20" water column: 0.42 scfm/ft ²
	0.30" water column: 0.66 scfm/ft ²
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and ETL label.
APPROVAL:	Listed as a smoke and draft control system for use with separately listed fire-rated elevator hoistway doors. For use where allowed by the California Building Code and the authority having jurisdiction. Refer to listee's Installation Instruction Manual for details.
NOTES:	This item is for nonstructural applications and NO hose stream tests were conducted.

9-24-21 VWW





CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/27/2022

Listing Expires: 06/30/2023

Authorized By: Victor Wong, Program Coordinator Fire Engineering & Investigations Division