U.S. SMOKE & FIRE®

FIRE PROTECTIVE SMOKE CURTAINS DIVISION 8

Designated as High Priority Openings

1. OPENINGS IN SMOKE PARTITIONS

- Non-Hose Stream Tested
- UL 10B 20 minute no hose
- ASTM E136
- ASTM E84

→

- SD60® Smoke Curtain® (Full Drop / Half Drop to Floor)
- SD60® Deployable Draft Curtain (18" Drop up to 24" drop)
- SD60® Fixed Fabric Draft Curtain

2. ELEVATOR HOISTWAY SMOKE CONTAINMENT

- ICC AC 77, CCRR 0418, ICC 3322

→

- SD60GS® Side Guide Seal Elevator Smoke Containment®

2. ELEVATOR HOISTWAY SMOKE CONTAINMENT

- ICC AC 77, ESR 4888

→

- ESC Magnetic Seal Elevator Smoke Containment

3. OPENINGS IN SMOKE BARRIER WALLS AND FIRE PARTITION WALLS

- UL 10D
- UL 1784
- Not Hose Stream Tested

→

- SD60GS® 1 Hr Fire Protective Smoke Curtain with Egress
- SD240GS® 3 Hr Fire Protective Smoke Curtain
- SD240GS® 3 Hr Fire Protective Smoke Curtain with Integral Swing Door or Pass Through Slot
- SD240A® 3 Hr Accordion Curtain for Corner Conditions with Egress

U.S. Smoke and Fire Corporation. © Copyright 2026.

www.ussmokeandfire.com
www.ussmokeandfirecurtain.com
888.917.8777